

Contact person RISE
Ulrika Johansson
Chemistry and Materials
+46 10 516 53 22
ulrika.johansson@ri.se

Date
2018-10-02

Reference
8F019795-11

Page
1 (1)

Daloc AB
Julia Hellberg
Box 43
545 21 TÖREBODA

Assessment of Compliance

Emission measurements according to SS-EN ISO 16000-9:2006 regarding volatile organic compounds (VOC and VVOC/SVOC), carcinogenic substances and formaldehyde after 28 days have been performed on steel doors with the product names **Daloc Ståldörr Målad korrosivitetssklass**, see the test report 8F019795-7 dated 2018-10-01.

Byggvarubedömningen has criteria regarding Emissions to indoor environment. The emissions are measured according to a standard method such as ISO 16000-9. The requirements for the *Accepted class* is that the requirements to one of the following systems are being met: Emission EC2, AgBB or M2 (RTS).

The emission results for the tested product is compared to the requirements of AgBB (Feb 2015).

Compounds	Requirement AgBB ($\mu\text{g}/\text{m}^3$)	Test Results Daloc Ståldörr Målad korrosivitetssklass ($\mu\text{g}/\text{m}^3$)	Pass / Fail
TVOC after 28 days	$\leq 1\ 000$	190	PASS
TSVOC after 28 days	≤ 100	55	PASS
Any CMR 1A+1B after 28 days	≤ 1	< 1	PASS
R-value after 28 days	≤ 1	0.44	PASS
Sum of non-assessable VOC after 28 days	≤ 100	< 5	PASS

The tested product **Daloc Ståldörr Målad korrosivitetssklass** is in compliance with the tested requirements of AgBB (Feb 2015) and with the Accepted class according to Byggvarubedömningen.

RISE Research Institutes of Sweden AB Chemistry and Materials - Chemistry

Performed by

Examined by

Ulrika Johansson

Tove Malin

RISE Research Institutes of Sweden AB

Postal address
Box 857
SE-501 15 BORÅS
Sweden

Office location
Brinellgatan 4
SE-504 62 BORÅS

Phone / Fax / E-mail
+46 10 516 50 00
+46 33 13 55 02
info@ri.se

This document may not be reproduced other than in full, except with the prior written approval of RISE.